



GELT INTERNATIONAL
scientific consulting

“Small Tower” Germicidal and antiviral activity assessment

UVC999 S.L.
ESB-02829968 P.I. Estepona,
c/Fahrenheit n3, 29680,
Estepona Malaga Spain

The device called “**Small Tower**” sold by UVC999 SL has been tested for:

- *Serratia marcescens* (Gram-negative bacteria), according to ISO 15714: 2019 *Method of evaluating the UV dose to airborne microorganisms transiting in-duct ultraviolet germicidal irradiation*, limited to what applicable. Test performed at 40 m³/h; > 99% of inactivation of testing microorganism.
- SARS-CoV-2_COV2019 ITALY/INMI1 with static exposure at < 1 second of contact time (corresponding to 40 m³/h rate); > 99% of inactivation of the testing virus.

No. 22TR0143/01
Issue date
23/03/2022